


Filling device de luxe



Filling device de luxe



Adapter for pipes DN70 or DN80.


If the adapter is installed the cap of the filter can not be lifted for cleaning the filter insert. This is because the pipe stands on the adapter.

In this case you have to loosen the downpipe in order to lift it and clean the insert.

Filling device de luxe



Downpipe
DN 100



Cover cap for downpipe **DN 100**.
The pipe sticks a little in the cover
cap. The cover cap can be lifted for
cleaning the filter insert as shown
in the instructions.

